

|          |                        |              |                |
|----------|------------------------|--------------|----------------|
| Date:    | 9/18/2017              | Addendum No: | 2              |
| Project: | Sorenson Senior Living | Project No:  | 111-17-07      |
| To:      | Bob Engel              | Firm:        | RWE Architects |

**NOTICE**

**THIS ADDENDUM IS ISSUED BY THE ENGINEER TO ALL KNOWN PARTIES WHO HAVE RECEIVED BIDDING DOCUMENTS FOR THE ABOVE LISTED PROJECT. THIS ADDENDUM SHALL BECOME PART OF THE CONTRACT DOCUMENTS AS A REVISION TO THE ORIGINAL DOCUMENTS.**

**CONSTRUCTION DOCUMENTS**

**SHEET M4.0**

1. Mechanical Specifications, Section 15150: 'Added 7. NPS 1-1/4 to NPS 8: Hubless, PVC soil piping and fittings if approved by Authority Having Jurisdiction.' to Section 1.1 'Piping Materials', Sub-section F 'Aboveground, Soil, Waste, and Vent Piping'.

**END OF ADDENDUM NO. 2**

**Attachments:**

111-17-07, M4.0, Mechanical Specifications (1 of 2)

**By: Ricky D. Hiatt, P.E., CEM, LEED AP  
Engineer**

